An ISO 9001:2008 Certified Company





Our Motto: "Engineering towards better future"

Fire Test certificate

API Standard 607, 7th Edition, 2016;

Certificate no: NVI/FS/100/02

Date:	19/05/2020
	19-05-2020

Name of the manufacturer	NEO VALVES INDUSTRIES	Test Date:	19-05-2020
Designation of valve	BALL VALVE	Drawing No & Rev.No	FBV-002, Rev-00
Manufacturing standard	API 6D/ BS EN 17292	Heat Nos (Body/T.P)	G0342
Size	4" (DN 100MM)	Pressure Rating	Class 150
Body / T.P Material	ASTM A216 Gr. WCB	Seat Material	PTFE
Tim Material	ASTM A276 TYPE.410	Stem Seal / Body seal	GRAFOIL
Fasteners	A193Gr.B7 &A194 Gr.2H	Test valve SI. No:	43684

The above valve is tested in accordance with the above stated fire test procedure. All of the applicable parameters were met and external and through seat leakage measurements were below the allowable limits. Other valves of the same construction may also be qualified according to the requirements of the fire test specification, section 7.

This certificate refers to the above mentioned product. This is to certify that the test specimen provided is in conformity with the standard mentioned above. This certificate does not imply assessment of the production of the product.

Sizes qualified	DN 100;125 ;150; 200	Pressure Rating	150# & 300#	
-----------------	----------------------	-----------------	-------------	--

Test Witnessed by



TUV INDIA PVT.LTD.

#116, Ground Floor, West of chord road, 1st block, 2ndstage ,Rajaji Nagar, Bangalore-560086. Karnataka- INDIA,

Ph.No.:080-46023456

Website: www.tuv-nord.com/in/en/home/

TIV India * Provide

KRISHNA KALWAD- SURVEYOR

H.O.: # 90 F, KIADB, 2nd Phase, Tarihal Industrial Estate, HUBLI - 580 026. Karnataka - INDIA.

Telefax: 0836-2330627 • Cell: +91-9845254403

e-mail: neovalves@yahoo.co.in • Web: www.neovalves.in / www.facebook.com/NEOVALVES

An ISO 9001:2008 Certified Company





Our Motto: "Engineering towards better future"

Fire Test Certificate

API Standard 607, 7th Edition, 2016;

Certificate no: NVI/FS/50/01

Date: 19/05/2020

Name of the manufacturer	Neo Valves Industries	Test Date:	19-05-2020
Designation of valve	BALL VALVE	Drawing No & Rev. No	NVI/BV/FS/01 Rev -00
Manufacturing standard	API 6D / BS EN 17292	Heat Nos (Body/T.P):	G0546, 9B2
Size	2" (DN 50MM)	Pressure Rating	Class 150
Body /T.P Material	ASTM A216 GR. WCB	Seat Material	PTFE
Tim Material	ASTM A276 TYPE410	Stem Seal / Body seal	Grafoil
Fasteners	A193Gr.B7 & A194 Gr.2H	Test valve SI.No:	43683

The above valve is tested in accordance with the above stated fire test procedure. All of the applicable parameters were met and external and through seat leakage measurements were below the allowable limits. Other valves of the same construction may also be qualified according to the requirements of the fire test specification, section 7.

This certificate refers to the above mentioned product. This is to certify that the test specimen provided is in conformity with the standard mentioned above. This certificate does not imply assessment of the production of the product.

Sizes qualified	DN 50 and below,65;80;100	Pressure Rating	150# &300#

Test Witnessed by



TUV INDIA PVT.LTD.

#116, Ground Floor, West of chord road, 1st block, 2ndstage ,Rajaji Nagar, Bangalore-560086. Karnataka- INDIA,

Ph.No.:080-46023456

Website: www.tuv-nord.com/in/en/home/

KRISHNA KALWAD- SURVEYOR

H.O.: # 90 F, KIADB, 2nd Phase, Tarihal Industrial Estate, HUBLI - 580 026. Karnataka - INDIA. Telefax: 0836-2330627 • Cell: +91-9845254403

e-mail: neovalves@yahoo.co.in • Web: www.neovalves.in / www.facebook.com/NEOVALVES